

# The Odisha Gazette

EXTRAORDINARY  
PUBLISHED BY AUTHORITY

---

No. 2433 CUTTACK, MONDAY, DECEMBER 31, 2012/PAUSA 10, 1934

---

INDIAN RAILWAYS  
PUBLIC NOTIFICATION

CHARGING

The 31st December 2012

No. 305—EL-CON-BBS-EIG-OHE.—It is notified for information of the public that in connection with introduction of 25 KV AC Electric Traction over the noted section of East Coast Railway, height gauges have been erected at all the level crossing with clear height of 4.67 Mtr. above road level with a view to prevent loads of excessive height from coming into contact or dangerous proximity to live traction wire.

Public are hereby notified to observe the height specified above for the purpose of loading vehicles and to see that the loads carried in road vehicles do not infringe the height gauges under any circumstances.

The dangers of a load of excessive height are as follows :—

- (i) Danger to the height gauge and consequent obstruction to the road as well as the railway line.
- (ii) Danger to the materials or equipment carried or the vehicle itself.
- (iii) Danger of fire and risk of life due to contact with or dangerous proximity to the conductors.

Section : Electrification of MESCO Siding at Sukinda :

Sl. No.	Line	From Loc.	Chain age	To Loc.	Chain age	Length
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	LC Gate of MESCO in plant siding	MISL - 1/5	1/426.03	MISL - 1/8	1/453.03	26.00
					Total . .	26.00 MTR

MANJEET SINGH SANSANWAL

Dy. Chief Electrical Engineer/Con - I  
Bhubaneswar